



Certificate of Validation

GE Sealants & Adhesives

Has been granted the SWRI Certificate of Validation for

SilPruf SCS2000



It has been validated that this product performs as stated hereunder in the SWRI Priority Performance Properties Profile:

- ASTM C719 Adhesion and Cohesion of Elastomeric Joint Sealants Under Cyclic Movement [Hockman Cycle]; Pass: Extension: +50% Compression: -50%; Substrate: Aluminum, Glass & Mortar [GE SS4044P Primer was applied to mortar substrate]
- ASTM C661 Test Method for Indentation Hardness of Elastomeric - Type Sealants by Means of Durometer Hardness; Shore "A" Durometer Rating: 30

Supporting documentation is on file and available only on written requests submitted to SWRI headquarters.

Validation Date – February 25, 2003

Expiration Date – February 25, 2008

No. 203-SCS2208